

Custom Job
EXTENSION BY PHASE

Item #	Description	Qty	Price U	Ext Price	Labor U	Ext Labor
--- 01 Raceway, Ftgs, & Boxes ---						
1000	1/2" EMT	165	19.39 C	32.00	2.55 C	4.21
1001	3/4" EMT	3,345	30.84 C	1,031.59	2.73 C	91.32
1002	1" EMT	442	54.76 C	242.04	2.90 C	12.83
1004	1-1/2" EMT	16	99.76 C	15.96	3.48 C	0.56
1005	2" EMT	35	120.80 C	42.28	4.06 C	1.42
1006	2-1/2" EMT	85	185.29 C	157.50	5.22 C	4.44
--- 02 Wire & Cable ---						
2789	#14 THHN CU Stranded Wire	431	28.82 M	12.41	4.74 M	2.04
2790	#12 THHN CU Stranded Wire	61,239	42.19 M	2,583.70	5.80 M	355.15
2791	#10 THHN CU Stranded Wire	6,858	63.88 M	438.10	6.32 M	43.34
2792	#8 THHN CU Stranded Wire	1,420	104.76 M	148.76	6.59 M	9.36
2793	#6 THHN CU Stranded Wire	188	171.91 M	32.32	7.38 M	1.39
2794	#4 THHN CU Stranded Wire	5,646	262.38 M	1,481.39	8.96 M	50.58
2795	#3 THHN CU Stranded Wire	571	326.29 M	186.32	9.48 M	5.41
2797	#1 THHN CU Stranded Wire	104	522.09 M	54.30	11.59 M	1.21
2798	#1/0 THHN CU Stranded Wire	745	546.10 M	406.85	13.70 M	10.21
--- 03 Distribution ---						
A	225 Amp Surf Panel-Nema 1	1	QUOTE 2	0.00	7.80 E	7.80
B	125 Amp Surf Panel-Nema 1	8	QUOTE 2	0.00	5.27 E	42.16
E	225 Amp Surf Panel-Nema 1	1	QUOTE 2	0.00	8.75 E	8.75
P	225 Amp Surf Panel-Nema 1	1	QUOTE 2	0.00	8.38 E	8.38
E1	400 Amp Surf Panel-Nema 1	1	QUOTE 2	0.00	9.54 E	9.54
E2	400 Amp Surf Panel-Nema 1	1	QUOTE 2	0.00	8.14 E	8.14
T1	75 KVA 3PH Transformer 480V X 208V	1	QUOTE 2	0.00	14.65 E	14.65
T2	30 KVA 3PH Transformer 480V X 208V	1	QUOTE 2	0.00	20.14 E	20.14
--- 04 Light Fixtures & Lamps ---						
I	H.I.D. Four Head Pole Top Fixture	1	QUOTE 1	0.00	3.69 E	3.69
A	2'x4' Fluor Lay-In	24	QUOTE 1	0.00	0.47 E	11.28
C	4' Wrap-Around 2-Lamp	10	QUOTE 1	0.00	0.58 E	5.80
E	Exit Fixture W/Batt Pack	3	QUOTE 1	0.00	0.58 E	1.74
F	3' Wall Fluor	2	QUOTE 1	0.00	0.47 E	0.94
G	Double traffic Red/Green	18	QUOTE 1	0.00	0.58 E	10.44
J	Compact Fluor Recessed Downlight	10	QUOTE 1	0.00	0.47 E	4.70
L	H.I.D. Wall Pack Fixture	3	QUOTE 1	0.00	0.95 E	2.85
M	H.I.D. Recessed Fixture	18	QUOTE 1	0.00	0.84 E	15.12
--- 05 Wiring Devices & Covers ---						
4448	15A Comp Grade SP Switch	8	71.54 C	5.72	0.16 E	1.28
4459	20A Spec Grade SP Switch	14	835.80 C	117.02	0.16 E	2.24
4483	20A Spec Grade 3-Way Switch	4	707.53 C	28.30	0.26 E	1.04
4511	20A/125V Spec Grade Dup Rcpt (5-20R)	51	121.31 C	61.87	0.16 E	8.16
4518	20A/125V Spec Grade GFI Dup Rcpt (5-	15	10.00 E	150.00	0.20 E	3.00
4519	20A/125V PremSpec Grde GFI Duplex(5-	4	63.35 E	253.40	0.20 E	0.80
4662	15A Clock Receptacle (Stnls Steel)	3	27.30 E	81.90	0.32 E	0.96
--- 07 Misc ---						
2043	2" Weatherhead	4	1,164.60 C	46.58	0.68 E	2.72
2047	4" Weatherhead	3	148.69 E	446.07	2.50 E	7.50
2162	1" GRC Elbow	16	368.50 C	58.96	0.38 E	6.08
2550	3/8" All Thread	67	67.89 C	45.15	6.63 C	4.41
3107	1/8" Poly Pull Line	200	6.92 M	1.38	2.11 M	0.42
6378	SPST 40A/208-277V 24 Hr Time Switch	1	57.91 E	57.91	1.37 E	1.37
--- 08 Special Systems ---						
8345	Duct Detector	2	QUOTE 6	0.00	1.90 E	3.80
8379	Test Station DD	2	QUOTE 6	0.00	1.05 E	2.10
--- 08 Special Systems Total ---				0.00		5.90
Job Total				201,151.21		5,949.83